



NO.	REVISION	DATE

VIBRATION ELIMINATOR CO., INC.
 15 Dixon Avenue
 Copiague, New York 11726

HORIZONTAL
 RUBBER-IN-SHEAR
 SNUBBER

DWG. NO. JL97281

1. PLACE SNUBBER AS SHOWN ON DRAWING.
2. SNUBBER MUST BE PLACED AGAINST BASE AND SECURED TO DECK BEFORE FAN IS STARTED.